

Tabela regulacyjna wody sieciowej
dla sieci ciepłej miasta Sieradza
CM 1 całość 2020/2021

T zew	T zasilanie	T powrót
-18	120	70
-17	118,5	69
-16	117	68
-15	115	67
-14	113	66
-13	111	65
-12	109	64
-11	107	63
-10	105	62
-9	103	61
-8	101	60
-7	98,5	59
-6	96,5	58
-5	94,5	57
-4	92,5	56
-3	90	55
-2	87,5	54
-1	85,5	53
0	82,5	52
1	80	51
2	78	50
3	76	49,5
4	74,5	49
5	73	48,5
6	71,5	48
7	70	47,5
8	70	48
9	70	48,5
10	70	49
11	70	50
12	70	51

Lato 2021

temperatura zasilania - 70 °C
temperatura powrotu ~ 50 °C